

UBC Nano Chillers

Warranty Coverage Guidelines:

- BTU Load must be accurately calculated and kept 10-20% below BTU rating of the Nano Chiller
- When changing system setup, re-evaluate that BTU loads are in range of chiller
- Ensure compressor is not overloaded by making sure the:
 - Compressor does not run constantly
 - Temperature set by the controls is being reached
 - Compressor is regularly cycling to maintain set temperature
- Require regular maintenance inspections for operating within initial installed parameters

